

DF-3 Gas

Train

9/13/2011

BILL OF MATERIALS


ITEM NUMBER	Description	Quantity
1	1" Quick Seal	1
2	1" x 3-1/2" Nipple	1
3	1" 90° Elbow	2
4	1" x Close Nipple (1-1/2")	4
5	1" Union	3
6	1" x 1" x 1/4" Tee	2
7	-5-15 w.c. Gas Pressure Gauge	1
8	1" x 2" Nipple	4
9	Robertshaw 7000DERHC 1" Combination Valve	1
10	Maxitrol M611 1" Modulating Valve	1
11	1" Manual Ball Valve	1
12	1" x 7" Nipple	1
13	1" x 8" Nipple	1
14	12", 18" or 24" Midco Dual Fuel Burner	1
15	1-1/2" to 1" 90° Reducing Elbow	1
16	1-1/2" x Close Nipple (1-3/4")	1
17	0-35" w.c. Gas Pressure Gauge	1

NOTES:
 Gas Type: Natural or LP
 Inlet Pressure: 7 in. w.c. - 14 in. w.c.
 Max. Natural Gas Manifold Pressure: 5 in. w.c.
 Max. LP Manifold Pressure: 2.5 in. w.c.

External Ball Valve Shipped Loose in Control Cabinet

External High Gas Pressure Regulator Required when gas pressure exceeds 14 in. w.c.:
 P/N = 143-80-2-1-G-5/8 (10 psi. max.)

Standard Gas Train



Material: N/A
 Blank Size: N/A x N/A
 Weight: N/A lbs

Part Number: N/A
 MACOLA/AX Number:
 Drawing Name: DF 3 Gas Train
 Drawn By: BRH
 Parent Assembly: DF 3
 Sheet: 2 of 4


Unless Otherwise Specified
 Dimensions are in Inches.
 Standard Tolerances are:
 Fractions: ±1/16
 Decimal: .XX±.05
 .XXX±.015
 Angles: ±1°

CONFIDENTIAL

BILL OF MATERIALS

ITEM NUMBER	Description	Quantity
1	1" Quick Seal	1
2	1" x 3-1/2" Nipple	1
3	1" 90° Elbow	2
4	1" Close Nipple (1-1/2")	4
5	1" Union	3
6	1" x 1" x 1/4" Tee	2
7	1/4" Square Head Pipe Plug	2
8	1" x 2" Nipple	4
9	Robertshaw 7000DERHC 1" Combination Valve	1
10	Maxitrol M611 1" Modulating Valve	1
11	1" Manual Ball Valve	1
12	1" x 7" Nipple	1
13	1" x 8" Nipple	1
14	12", 18" or 24" Midco Dual Fuel Burner	1
15	1/4" Close Nipple (1")	4
16	1/4" x 1/4" x 1/4" Tee	2
17	Optional Antunes HGP-A M1 Pressure Switch	1
18	Optional Antunes LGP-A M1 Pressure Switch	1
19	1" to 1-1/2" 90° Reducing Elbow	1
20	1-1/2" Close Nipple (1-3/4")	1

Gas Train w/Pressure Switch



NOTES:
 Gas Type: Natural or LP
 Inlet Pressure: 7 in. w.c. - 14 in. w.c.
 Max. Natural Gas Manifold Pressure: 5 in. w.c.
 Max. LP Manifold Pressure: 2.5 in. w.c.

External Ball Valve Shipped Loose in Control Cabinet

External High Gas Pressure Regulator Required when gas pressure exceeds 14 in. w.c.:
 P/N = 143-80-2-1-G-5/8 (10 psi. max.)

Material: N/A
 Blank Size: N/A x N/A
 Weight: N/A lbs

Part Number: N/A
 MACOLA/AX Number:
 Drawing Name: DF 3 Gas Train
 Drawn By: BRH
 Parent Assembly: DF 3
 Sheet: 3 of 4

Unless Otherwise Specified
 Dimensions are in Inches.


Standard Tolerances are:
 Fractions: ±1/16
 Decimal: .XX±.05
 .XXX±.015
 Angles: ±1°

CONFIDENTIAL

BILL OF MATERIALS

Gas Train w/Upstream Pilot

ITEM NUMBER	Description	Quantity
1	1" Quick Seal	1
2	1" x 3-1/2" Nipple	1
3	1" 90°Elbow	2
4	1" Close Nipple (1-1/2")	4
5	1" Union	3
6	1" x 1" x 1/4" Tee	2
7	-5-15 w.c. Gas Pressure Gauge	1
8	1" x 2" Nipple	4
9	Robertshaw 7000DERHC 1" Combonation Valve	1
10	Maxitrol M611 1" Modulating Valve	1
11	1" Manual Ball Valve	1
12	1" x 7" Nipple	1
13	1" x 8" Nipple	1
14	12", 18" or 24" Midco Dual Fuel Burner	1
15	1/4" Close Nipple (1")	4
16	1/4" x 1/4" x 1/4" Tee	1
17	1/4" x 2" Nipple	1
18	1/4" 90 Elbow	2
19	1" to 1-1/2" 90°Reducing Elbow	1
20	1-1/2" Close Nipple (1-3/4")	1
21	1/4" Manual Ball Valve	1
22	RV20LW-22-0002 1/4" Regulator	1
23	V4046C1021 Solenoid Valve	1
24	1/4" Brass 90 Elbow	1
25	0-35" w.c. Gas Pressure Gauge	1



NOTES:
 Gas Type: Natural or LP
 Inlet Pressure: 7 in. w.c. - 14 in. w.c.
 Max. Natural Gas Manifold Pressure: 5 in. w.c.
 Max. LP Manifold Pressure: 2.5 in. w.c.

External Ball Valve Shipped Loose in Control Cabinet

External High Gas Pressure Regulator Required when gas pressure exceeds 14 in. w.c.:
 P/N = 143-80-2-1-G-5/8 (10 psi. max.)

Material: N/A
 Blank Size: N/A x N/A
 Weight: N/A lbs

Part Number: N/A
 MACOLA/AX Number:
 Drawing Name: DF 3 Gas Train
 Drawn By: BRH
 Parent Assembly: DF 3
 Sheet: 4 of 4

Unless Otherwise Specified
 Dimensions are in Inches.
 Standard Tolerances are:
 Fractions: ±1/16
 Decimal: .XX±.05
 .XXX±.015
 Angles: ±1°

CONFIDENTIAL