



|                  |             |
|------------------|-------------|
| Model #          | CBK         |
| Serial #         |             |
| Kilowatts        | 36.00       |
| Volts/Ph/Hz      | 460 / 3/ 60 |
| Control Volts    | 24          |
| Steps            | 2           |
| Heater Amps      | 43.3        |
| Heater Fuses     | N/A         |
| System Amps.     | N/A         |
| V.A.             | 21.0        |
| Min. F.P.M.      | 1150        |
| Min. Wire Ga. CU | # 6 AWG     |
| Control Wiring   | -----       |
| Power Wiring     | -----       |
| Other Wiring     | -----       |

NOTE :

- \*Replace one shot therm-D-disc with L300F-61F14/L300F-60FXX14, use copper wire only suitable for at least 75°C.
- \*\* Replace auto-reset with thermo disc type 60TX11-L145
- \*\*\*Replace manual-reset with thermo disc type 60TX11-L175

-FIELD WRING,NEC Class I.

|                          |   |
|--------------------------|---|
| <b>WARREN TECHNOLOGY</b> |   |
| Aprv. by DJG             | RUPP AIR MANAGEMENT<br>SCHEMATIC Wiring Diagram |
| Rev. by B.NGHIEM         | MODEL EC1<br>36 KW 480/3                        |
| Date : 12/30/03          | Dwg: RUP\EC\WEC1RP3605                          |