



Model #	CBK
Serial #	
Kilowatts	9.90
Volts/Ph/Hz	208 / 1 / 60
Control Volts	24
Steps	2
Heater Amps	47.60
Heater Fuses	N/A
System Amps.	N/A
V.A.	15.0
Min. F.P.M.	500
Min. Wire Ga. CU	# 6 AWG
Control Wiring	-----
Power Wiring	-----
Other Wiring	-----

NOTE :

- *Replace fuse links with G5-AM0400152C, use copper wire only suitable for at least 75° C
- ** Replace auto-reset with thermo disc type 60TX11-L145
- ***Replace manual-reset with thermo disc type 60TX11-L175
- FIELD WIRING, NEC Class I.

WARREN TECHNOLOGY

Aprv. by DJG	RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram
Rev. by B.NGHIEM	MODEL EC11 9.9KW 208/3
Date : 12/30/03	Dwg: RUP\EC\WEC11RP1001