



Model #	CBK
Serial #	
Kilowatts	83.00
Volts/Ph/Hz	460 / 3 / 60
Control Volts	24
Steps	3
Heater Amps	99.83
Heater Fuses	45
System Amps.	N/A
V.A.	27.0
Min. F.P.M.	1010
Min. Wire Ga. CU	# 1 AWG
Control Wiring	
Power Wiring	
Other Wiring	

NOTE :
 *Replace one shot therm-D-disc with L300F-61F14/L300F-60FXX14, use copper wire only suitable for at least 75°C.
 ** Replace auto-reset with thermo disc type 60TX11-L145
 ***Replace manual-reset with thermo disc type 60TX11-L175
 -FIELD WRING, NEC Class I.

WARREN TECHNOLOGY	
Aprv. by DJG	RUPP AIR MANAGEMENT SCHEMATIC Wiring Diagram
Rev. by B.NGIEM	MODEL EC3 83 KW 480/3
Date : 12/30/03	Dwg: RUP\EC\WEC3RP8305